

# TYPE TEST REPORT

NO. 2598.2110041.0628

Elsewedy SEDCO - Subsidiary of Elsewedy Electric 5 <sup>th</sup> Settlement New Cairo 11835 EGYPT	CLIENT
------------------------------------------------------------------------------------------------------------	--------

Elsewedy SEDCO - Subsidiary of Elsewedy Electric <b>South (A'1) Industrial Region</b> 10 <sup>th</sup> of Ramadan City EGYPT	MANUFACTURER
---------------------------------------------------------------------------------------------------------------------------------------	--------------

Connector	TEST OBJECT
-----------	-------------

Compression (crimping) type	TYPE
-----------------------------	------

Test samples (Internal code: STCC 11102002011120)	SERIAL NO.
---------------------------------------------------	------------

Nominal cross-sectional area	240 mm <sup>2</sup>	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Conductor material	Copper	
Type of conductor	Round, stranded	
Class	A	

IEC 61238-1: 2003-05	NORMATIVE DOCUMENT
----------------------	-----------------------

Type tests: • Electrical tests (Heat cycle and short-circuit tests) • Mechanical test	RANGE OF TESTS PERFORMED
---------------------------------------------------------------------------------------------	-----------------------------

08 June to 30 September 2011	DATE OF TEST
------------------------------	--------------

The rated characteristics related to the range of tests performed have been verified. The tests have been PASSED.	TEST RESULT
----------------------------------------------------------------------------------------------------------------------	-------------



RONALD BORCHERT  
Senior engineer  
Berlin, 10 January 2012



DAGMAR HAUSCHILD  
Test engineer in charge