

TYPE TEST CERTIFICATE OF COMPLETE TYPE TEST

OBJECT	66 kV pre-moulded straight-through joint
DESIGNATION	single-core 69 TCJ-N1R
Rated voltage U_r/U_m	39,8/69/72,5 kV
Rated frequency	50 Hz
MANUFACTURER	ELASTIMOLD EGYPT PC # 36 A - South (A'1) - Industrial Region - 10 th of Ramadan City - Egypt
TESTED FOR	EL SEWEDY Obour Buildings No. 13 - Salah Salem St. - Nasr City - Egypt
DATE OF TESTS	8 May 2003 until 5 June 2003
TESTED BY	KEMA HIGH-VOLTAGE LABORATORY Utrechtseweg 310 - 6812 AR Arnhem - the Netherlands

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60840

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 1.

The Certificate applies only to the object tested. The responsibility for conformity of any object having the same designations with that tested rests with the manufacturer.

This Certificate comprises 16 sheets in total.

© Copyright: Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the endorsed ratings of the object tested, are permitted without written permission from KEMA.
Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.

KEMA Nederland B.V.



S.A.M. Verhoeven

Arnhem, 9 July 2003

