

## KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

**Elsewedy Transformers**

Cairo, Egypt

for the test object:

A three-phase dry-type distribution

**transformer**

Type: SWD 1500/11

Rating: 1500 kVA – 11 kV  $\pm 2 \times 2,5\%$  / 415 V – Dyn11 – 50 Hz

manufactured by

**Elsewedy Transformers** a CESI brand

Cairo, Egypt

The test object has successfully passed the required type tests of

**IEC 60076-11**

The test results are recorded in Certificate No.

**2179-20**

This Certificate was first issued on 19 November 2020.

KEMA B.V.



Shankar Subramany  
Director, High-Power Laboratory