

Type test Certificate of short-circuit performance

El-Sewedy Cables (Transformers Factory)

Cairo, Egypt

has successfully passed the type test sequence on a

power transformer

Type: SFZ9-40000/66T

Rating: 40 MVA – 66 kV \pm 8 x 1,25% / 11,86 kV – Dyn11 – 50 Hz

The test object passed the specification of test duties of


IEC 60076-5

The test results are recorded in Certificate No.

TDT 2015-10

This Certificate is issued on 15 April 2010

KEMA Nederland B.V.



P.G.A. Bus
KEMA T&D Testing Services
Managing Director



Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.