

KEMA TYPE TEST CERTIFICATE OF SHORT-CIRCUIT PERFORMANCE

was issued to

Elsewedy Transformers

Cairo, Egypt

for the test object:

a three-phase oil-immersed

distribution transformer

Type: 3-phase oil immersed transformer

Rating: 250 kVA - 11 kV \pm 2 x 2,5% / 0,433 kV - Dyn11 - 50 Hz

manufactured by

Elsewedy Transformers

Cairo, Egypt

The test object has successfully passed the required type tests of

IEC 60076-5

The test results are recorded in Certificate No.

2417-17

This Certificate was issued on 14 February 2018.

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA

Laboratories

© DNV GL

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that DNV GL has certified or approved any object other than the specimen tested.

