

REPORT OF PERFORMANCE

474-08

APPARATUS A three-phase dry-type distribution transformer

> **TYPE** SERIAL No. 0005/2008 ES-1600-6

11 kV ± 2 x 2,5% / 400 V - 1600 kVA - Dyn11 - 50 Hz

CLIENT Elsewedy Transformers,

Cairo, Egypt

MANUFACTURER Elsewedy Transformers,

Cairo, Egypt

KEMA HIGH-POWER LABORATORY **TESTED BY**

Utrechtseweg 310 - 6812 AR Arnhem - The Netherlands

DATE(S) OF TESTS 12 December 2008

TEST SPECIFICATION The tests have been carried out in accordance with the client's instructions.

Test procedure and test parameters were based on IEC 60076-11.

This report applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This report consists of 24 sheets in total.

This report falls under the scope of the accreditation certificates L 020 and L 218 of the Dutch Council for Accreditation. See information sheet (page 2).

> © Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The sealed and bound version of the report is the only valid version.

> > KEMA Nedelland B.V.

KEMA T&D Testing Services

Managing Director

Arnhem, 20 May 2009