

## Certificate of Product Approval

Certificate Number: 1716a

Issue: 01

### ELSEWEDY CABLES - KSA

Yanbu,  
Light Industry Area, Al Razi St.  
Yanbu 41912, Saudi Arabia 31670,  
Kingdom of Saudi Arabia

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
Fire Guard 1000 Plus

#### Standard(s) (see Appendix for details)

BS 7846:2015 (Category F2 & F120)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Al-eesa*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Manager

10 October 2022  
Date of Issue

10 October 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB® is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1716a ELSEWEDY CABLES - KSA

Issue: 01

Product name		LPCB Ref. No.
Fire Guard 1000 Plus		1716a/01
Nominal csa of conductor (mm <sup>2</sup> ) (See note 1)	Core Construction	BS 7846 (See note 2)
10	2, 3, 4 & 5	F2 & F120
16	2, 3, 4 & 5	F2 & F120
25	2, 3, 4 & 5	F2 & F120
35	2, 3, 4 & 5	F2 & F120
50	2, 3, 4 & 5	F2 & F120
70	2, 3, 4 & 5	F2 & F120
95	2, 3 & 4	F2 & F120
120	2, 3 & 4	F2 & F120
150	2, 3 & 4	F2 & F120
185	2, 3 & 4	F2 & F120
240	2, 3 & 4	F2 & F120
300	2, 3 & 4	F2 & F120
400	2, 3 & 4	F2 & F120

**Uo/U 600/1000V**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Aljeer*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Manager

10 October 2022  
Date of Issue

10 October 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1716a ELSEWEDY CABLES - KSA

Issue: 01

### Notes:

1. Stranded conductors only.
2. In meeting the requirements for BS 7846:2015 Category F2 & F120, the Fire Guard 1000 Plus cables listed met the fire resistance requirements of BS 6387:2013 Categories CWZ and BS 8491, achieved more than 70% smoke density when tested in accordance with EN 61034-2:2005 and achieved less than 0.5%HCl for the insulation, tapes, bedding & outer covering when tested in accordance with EN 60754-1:2014.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

<i>Obada Aljeer</i> Signed for BRE Global Ltd.	Obada Piracha Certification Manager	10 October 2022 Date of Issue	10 October 2022 Date of First issue
---	--	----------------------------------	--



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.

