

## Certificate of Product Approval

Certificate Number: 1716b

Issue: 01

### ELSEWEDY CABLES - KSA

Yanbu,  
Light Industry Area, Al Razi St.  
Yanbu 41912, Saudi Arabia 31670,  
Kingdom of Saudi Arabia

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
Fire Guard 100

#### Standard(s) (see Appendix for details)

BS 8592:2016

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Al-eesa*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Manager

30 November 2022  
Date of Issue

30 November 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB® is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1716b ELSEWEDY CABLES - KSA

Issue: 01

Product name		LPCB Ref. No.
FIRE GUARD 100		1716b/01
Nominal csa of conductor (mm <sup>2</sup> ) See Note 1	Core Construction	BS 8592 See note 2
10	one	Complies
16	one	Complies
25	one	Complies
35	one	Complies
50	one	Complies
70	one	Complies

### Uo/U 450/750V

#### Notes:

1. Stranded conductors only.
2. In meeting the requirements of BS 8592:2016, the FIRE GUARD 100 cables listed met the fire resistant requirements according to IEC 60331-3 for 120 minutes, requirements for smoke density according to EN 61034-2:2005 and achieved less than 0.5%HCl for the binding tape and outer covering when tested in accordance with EN 60754-1:2014.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Aljeer*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Manager

30 November 2022  
Date of Issue

30 November 2022  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.

