

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

was issued to

Elsewedy Transformers

Sharqia Governorate, Egypt

for the test object:

a three-phase oil-immersed

distribution transformer

Type: 3 phase oil immersed Transformer

Rating: 1500 kVA – 22 kV $\pm 2 \times 2,5\%$ / 415 V – Dyn11 – 50 Hz

manufactured by

Elsewedy Transformers

Sharqia Governorate, Egypt

The test object has successfully passed the required type tests of


**IEC 60076-1, IEC 60076-2, IEC 60076-3, IEC 60076-5,
IEC 60076-10**

The test results are recorded in Certificate No.

2094-21

This Certificate was first issued on 29 April 2021

KEMA B.V.



Shankar Subramany

Director, High-Power Laboratory